

DESIGN-EXAMINATION STATEMENT

Application of the
Council Directive 97/23/EC of 29 May 1997 on Pressure Equipment, as amended,
Article 3.3 and Swedish ordinance AFS 1999:4 §8

STATEMENT NO.: 13-GOT-539684-00

This Statement consists of 2 pages

THIS IS TO STATE THAT THE EQUIPMENT

Safety accessory

WITH THE TYPE DESIGNATION/EQUIPMENT DESCRIPTION

ERK

with electrode ENT 120/SH 1

MANUFACTURED BY

Elektro Relä AB

is found to comply with relevant parts of the requirements as to design in accordance with
the sound engineering practice of a Member State and AFS 2002:1, §17

The equipment has been examined with respect to N.A.

APPLICATIONS

Equipment Category: AFS 1999:4 8§ (Article 3.3)

Design Pressure min/max: Max 10 bar(g)

Design Temp. range: Max 110 °C


Fluid: Water

Further details of the product and conditions for the statement are given overleaf.

This Statement is valid until: 2017-05-07

MÖLNDAL, 2013-05-07

Inspecta Sweden AB



Mats Dahlrot
Senior Industrial Surveyor

Notice: The statement is subject to terms and conditions, if any, overleaf. Any significant changes in design or construction of the product, the quality system or amendments to the AFS 1999:4 (Directive 97/23/EC) or Standards referenced above may render this statement invalid. The product liability rests with the manufacturer or his representative in accordance with the AFS 1999:4 (Directive 97/23/EC), as amended.

DESIGN-EXAMINATION STATEMENT

STATEMENT NO.: 13-GOT-539684-00

INFORMATION

This statement is replacing certificate: no 07-GOT-784866-01, which has expired. This new device have same base construction as the previous ERK, different is that same components are replace by new type due the old type not are on the market any more.

SUPPORTING DOCUMENTS

Princip beskrivning konstruktion av ERK-TX

- Operating instructions Yes No
- Risk analysis Yes No


LIMITATIONS

This device should only be used as low water limiter for warm water heaters or vessels classified in §8 according to AFS 1999:4 (Article 3.3, directive 97/23/EC). With use on warm water heater, the device should have manual reset and lock out in case of external power failure.

Local country's legislations have to be taken into consideration.

MÖLNDAL, 2013-05-07

Inspecta Sweden AB



Mats Dahlrot
Senior Industrial Surveyor